

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006268A-R1
DATE: 10/25/05
CERTIFICATION PROGRAM: Structural
COMPANY: Bell View
CODE: B-153-1
REVISION DATE: 01/12/2010

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Bell-View, Inc. 150 Industrial Boulevard Wrightsville, GA 31096	Series "Blue Chip" Aluminum 1" Modular Fin Frame Picture Window Configuration: O Glazing: IG/SIG-3/16" AnGlass <u>STP PSF</u> Frame: W-3'11" Opening: W-3'8" Pos+60.0 H-5'11" H-5'8" Neg-60.0

SPECIFICATION	PRODUCT RATING
AAMA/NWWDA 101/L.S.2-97 ASTM F588-97 Glass Complies to ASTM E1300-04e1	F-C40 FER-Passed

Product Tested By: Certified Testing Laboratories
Report No: CTLA 1408W-9 (Structural/FER)/CTLA 1408W-10 (Gateway)
Expiration Date: September 30, 2011

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122