


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006302A-R1
DATE: 11/14/05
CERTIFICATION PROGRAM: Structural
COMPANY: Gallina
CODE: G-764-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Gallina USA, LLC 4335 Capital Circle Janesville, WI 53546	Series "0.280"(7mm) Corrugated Onda Plus Storm Panel" Polycarbonate Storm Panel Interior Wall-0.030"Thick/Exterior Wall- 0.030" Thick/Fluted Walls-0.010"Thick Overall Size: W-3'7" H-4'0"

SPECIFICATION	PRODUCT RATING
ASTM E330-02/ ASTM E1886-99/E1996-02	Design Pressure: +90/-90 psf Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3193-1 (Structural/Impact)/Revised 07/28/2006
Expiration Date: October 31, 2009

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659