

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006466-R1
DATE: 03/31/2006
CERTIFICATION PROGRAM: Structural
COMPANY: Dealers
CODE: D-786-1
REVISION DATE: 08/10/2009

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products at www.NAMICertification.com. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dealers Supply & Lumber Company 105 Airport Road Greenville, SC 29606 Configuration: OXXO Overall Size: W-9'5" H-8'2" Door Panel: W-3'0" H-7'11" Sidelites: W-1'6" H-8'0"	Series "1701 French Sidelite/1501 and 1518 French Door/1706 French Sidelite" Wood In-Swing Hinged Glass Door 1501 Panel: OG/1/8"TempGL 1518 Panel: 18 Lite/Muntins/OG/1/8"TempGL Left Sidelite: 6 Lite/Muntins/OG/1/8"TempGL Right Sidelite: OG/1/8"TempGL

SPECIFICATION	PRODUCT RATING
ASTM E330	Design Pressure: +47/-47 psf

Product Tested By: Architectural Testing, Fresno, CA
 Report No: ATI-53433.01-301-44 (Structural)/Parent-Rogue Valley-NI005865
 Expiration Date: **September 30, 2010**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122