

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009030
DATE: 07/31/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Gallina
CODE: G-764-1

The "Notice of Product Certification" is valid only when Administrator's Seal is applied to the upper left hand portion of this form and a certification label is applied to the product. This certification seal represents product conformity to the applicable specification and that all certification criteria has been satisfied.

The product described below is approved for listing in the next published issue of the Directory of Certified Products. Please review, and advise NAMI immediately if data, as shown, requires corrections.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Gallina USA, LLC 4335 Capital Circle Janesville, WI 53546	Series 16mm "RDC" Polycarbonate Storm Panel Material: 16mm Polycarbonate Overall Size: W-4'0" H-8'0"

SPECIFICATION	PRODUCT RATING
ASTM E330-02/ ASTM E1886-02/E1996-02	Design Pressure: +60/-60 psf Wind Zone 4-Missile Level D

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1712W
Expiration Date: July 31, 2011

Administrator's Signature: _____

A handwritten signature in black ink, consisting of several overlapping loops and strokes, positioned above a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

11870 Merchants Walk Suite 202

Newport News, VA 23606

TEL: (757) 594-8658

FAX: (757) 594-8659