

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI010516-R3</u>
DATE:	<u>02/08/2011</u>
CERTIFICATION PROGRAM:	<u>Fire</u>
COMPANY:	<u>Wincore</u>
CODE:	<u>1640-1</u>
REVISION DATE:	<u>02/28/2022</u>
EXPIRATION DATE:	<u>02/28/2032</u>

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Wincore Window Company, LLC 250 Staunton Turnpike Parkersburg, WV 26104</p>	<p>Plastpro's 20 Minute Flush or Embossed Fiberglass Single Swing Door Assembly</p> <p style="text-align: center;">SMC Fiberglass Embossed Skin Door w/Polyurethane Core For Single Swing Installation in 20 Minute Locations</p> <p style="text-align: center;">½" Minimum Latch Throw Single Swing Only</p> <p style="text-align: center;">Maximum Size: 3'0" x 6'8"</p>

SPECIFICATION	PRODUCT RATING
<p>NFPA 252 (2008) UL 10C (2001) (2009)</p>	<p>20 Minute-Without Hose Stream Positive Pressure Category B Door-Requires Additional Listed Edge Seal</p> <p style="text-align: center;">For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</p>

TEST REPORT	EVALUATION REPORT
<p>Intertek Test Report No: 31655MID-006/3182549MID-005b</p>	<p>Intertek Engineering Evaluation Report No: 3182549MID-008</p>

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com