


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010976-R6
DATE: 02/14/2012
CERTIFICATION PROGRAM: Fire
COMPANY: Provia Door
CODE: 1212-1
EXPIRATION DATE: 02/28/2026
REVISION DATE: 01/31/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia, LLC 2150 State Route 39 Sugarcreek, OH 44681	ProVia's Fiberglass Skin Routed Fiberboard Fiberboard Core Single Swing Door Fiberglass Skin Door with Fiberboard Core for single swing installation in 20 minute locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 7'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10C (2009) CAN4 S104 (1985)	20 Minute-With Hose Stream Positive Pressure Category B - Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT	EVALUATION REPORT
Intertek Test Report No: 100137063MID-005 NAMI Waiver of Retest: W-1907	Intertek Engineering Evaluation Report No: 100137063MID-006

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com