

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011402-R4
DATE: 01/16/2013
CERTIFICATION PROGRAM: Fire
COMPANY: Orepac
CODE: 1234-1
EXPIRATION DATE: 12/31/2024
REVISION DATE: 02/28/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Orepac Building Products, Inc. 30160 SW Orepac Avenue Wilsonville, OR 97070	20 Minute Positive Pressure Fire Door Assemblies w/Hose Stream Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single or Double Swing Only Maximum Size: 8'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) UL 10C (2009) UBC Standard 7-2 (1997)	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: AU10124008-1, 3058118-02, 3059877, J20012862-23, 3025659, 3137713COQ-007, 3151140COQ-004, 3168294MID-004b, 3004902, 3175675MID-004, 3058118-03, 3058118-02, 3187023MID-001, 3192291COQ-005, 3108034COQ-003/ Warnock-Hershey Report No: WHI-495-1525


 Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/nami@namiinc.com