

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011438-R7
DATE: 02/06/2013
CERTIFICATION PROGRAM: Fire
COMPANY: ProVia
CODE: 1212-1
REVISION DATE: 05/31/2023
EXPIRATION DATE: 02/28/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia, LLC 2150 State Route 39 Sugarcreek, OH 44681	90 Minute Positive Pressure Fire Door Assembly w/Hose Stream ProVia Legacy Steel Skin Door with Polyurethane Core for Single Swing Installation in 90 Minute Locations Cylindrical Latch with 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 7'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10C (2001/2009) CAN4 S104 (1985) CAN/ULC S104 (2010)	90 Minute-Positive Pressure With Hose Stream

TEST REPORT
Intertek Test Report No: 3172703MID-011, 100285991MID-003, 3172703MID-001/Intertek Engineering Evaluation Report No: 100415652MID-002, 100199935MID-003, 1008220052MID-002, N-190612.01 NAMI Waiver of Retest: W-1725/W-1906/W-2042/W-2069

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S.M.", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com