

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011913-R1
DATE: 03/24/2014
CERTIFICATION PROGRAM: Fire
COMPANY: Artistic
CODE: 1992-1
REVISION DATE: 08/31/2020
EXPIRATION DATE: 03/31/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Artistic Doors and Windows Manufacturing, LLC 10 South Inman Avenue Avenel, NJ 07001	90 Minute Glazed Composite Stile & Rail Fire Door Assembly w/Composite Frame Manufacturer Specific Fire Doors for Single Swing Installation in 90 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Glazing: 3/16" Firelite Single Door Maximum Size: 3'6" x 6'8" Minimum Thickness: 1-3/4" Glazing Maximum Size: 2'1" x 5'8"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) UL 10C (1998) UBC Standard 7-2 (1997)	90 Minute-Positive Pressure w/Hose Stream Category B Door-Additional Edge Seal Required For Use With Proprietary Composite Frame (or may also be installed in Category C-Frame in accordance with individual manufacturer's listing)

TEST REPORT

Intertek Test Report No.: 3060406
Intertek Engineering Evaluation No.: 3064606

A handwritten signature in black ink, appearing to be "MD", is written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122

