

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012220-R4
DATE: 12/17/2014
CERTIFICATION PROGRAM: Fire
COMPANY: Bright Wood
CODE: 2129-1
EXPIRATION DATE: 12/31/2027
REVISION DATE: 08/18/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Bright Wood Corporation 335 Northwest Hess Street Madras, OR 97741	<p style="text-align: center;">20 Minute Category C</p> <p style="text-align: center;">Proprietary Wood Door Frames</p> <p style="text-align: center;">Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations</p> <p style="text-align: center;">Single Door Maximum Size: 3'6" x 7'0"</p> <p style="text-align: center;">Minimum Thickness: 3-3/4"</p>

SPECIFICATION	PRODUCT RATING
UL 10C (1998) UBC Standard 7-2 (1997) UBC Standard 7-2 (1994)	20 Minute-With & Without Hose Stream Neutral Pressure Category C- Proprietary Frame

TEST REPORT
Warnock Hersey Test Report No: WHI-495-0509 Intertek Test Report No(s): 3746699, 8772599, 3028781, 3035264, 3048460 Priest & Assoc. Engineering Evaluation No: 10260


 Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com