

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012641-R3
DATE: 05/07/2015
CERTIFICATION PROGRAM: Fire
COMPANY: Orepac
CODE: 1234-1
EXPIRATION DATE: 05/31/2026
REVISION DATE: 04/11/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Orepac Building Products, Inc. 30160 SW Orepac Avenue Wilsonville, OR 97070	Taylor Building Product's 90 Minute Steel Single Swing Door w/Bayer Baytherm 3003 Core 22 Gauge Steel Skin Door w/Bayer Baytherm 3003 Core for single swing installation in 90 Minute locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 6'8" 914mm x 2032mm

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10C (2009) CAN4 S104(1985)	90 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame

TEST REPORT
Intertek Test Report No: 3193924MID-007

Administrator's Signature: 

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com