

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012650-R2  
DATE: 05/11/2015  
CERTIFICATION PROGRAM: Fire  
COMPANY: BMC Millwork  
CODE: 1665-1  
REVISION DATE: 06/29/2023  
EXPIRATION DATE: 05/31/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>BMC Millwork</b> <b>399 Northpoint Parkway</b> <b>Acworth, GA 30102</b>	<b>20 Minute Neutral Pressure Fire Door</b>  <b>Assemblies w/o Hose Stream</b>  Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single or Double Swing Only  <b>Maximum Size: 8'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (1999)</b> <b>UL 10B (2009)</b> <b>UBC Standard 7-2 (1997)</b>	<b>20 Minute-Neutral Pressure</b> <b>Without Hose Stream</b>

TEST REPORT
<b>Intertek Test Report No: 3073067, 3043898, 307008-1, 100108677COQ-001, 3059877, J20012862-23, 3025659, 3192291COQ-005, 3048495, 3108034COQ-003, Warnock-Hershey Test Report No: WHI-495-1685, WHI-495-1197, WHI-495-0897</b>

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)