

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012765-R4  
DATE: 07/30/2015  
CERTIFICATION PROGRAM: Fire  
COMPANY: Dyke Industries  
CODE: 452-1  
REVISION DATE: 11/14/2023  
EXPIRATION DATE: 07/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Dyke Industries</b> <b>10500 Northwest 95<sup>th</sup> Avenue</b> <b>Medley, FL 33178</b>	<b>Jeld Wen 20 Minute Neutral</b> <b>Pressure Steel Side-Hinged Door</b> <b>Assembly</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>Single Swing Maximum Size: 3'6" x 6'8"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)</b> <b>UL 10B (2009)</b> <b>UBC 7-2 (1994)</b>	<b>20 Minute-Neutral Pressure</b> <b>Without Hose Stream</b> <b>Category B - Additional Edge Sealing</b> <b>Required</b>

TEST REPORT
<b>Intertek Test Report No: WHI 495-0897, 100108677COQ-001, 100211525COQ-001, 100237214MID-001, 100754937MID-001</b>

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway**

**Hayes, VA 23072**

**Tel: (804) 684-5124**

**[nami@namiinc.com](mailto:nami@namiinc.com)**

NOPC 03/30/2023