

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012797-R3
DATE: 08/12/2015
CERTIFICATION PROGRAM: Fire
COMPANY: 3-G Trim
CODE: 2182-1
REVISION DATE: 07/31/2025
EXPIRATION DATE: 08/31/2030

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
3-G Trim, Incorporated 1820 East Deer Valley Road Phoenix, AZ 85024	20 Minute Category C Proprietary Wood Door Frames Manufacture Specific Fire Door Frames for Single and Double Swing Installation in 20 Minute Locations Single Door Maximum Size: 4'0" x 9'0" Double Door Maximum Size: 8'0" x 9'0" Minimum Thickness: 3-3/4"

SPECIFICATION	PRODUCT RATING
UL 10C (1998) UBC Standard 7-2 (1997) UBC Standard 7-2 (1994)	20 Minute-With & Without Hose Stream Positive Pressure Category C- Proprietary Frame

TEST REPORT
Warnock Hersey Test Report No: WHI-495-0509 Intertek Test Report No(s): 3746699, 8772599, 3028781, 3035264, 3048460 Priest & Assoc. Engineering Evaluation No: 10260

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023