

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012872-R2
DATE: 09/29/2015
CERTIFICATION PROGRAM: Fire
COMPANY: Provia
CODE: 1212-1
REVISION DATE: 09/07/2023
EXPIRATION DATE: 09/30/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia, LLC 2150 State Route 39 Sugarcreek, OH 44681	<p style="text-align: center;">90 Minute Single Swing</p> <p style="text-align: center;">Foam Filled Hollow Flush</p> <p style="text-align: center;">Steel Fire Door Assembly</p> <p style="text-align: center;">Configuration: X 24 Gauge Steel Skin Door w/Foam Filled Core for Single Swing Installation in 90 Minute Locations</p> <p style="text-align: center;">Maximum Size: 3'6" x 8'0"</p> <p style="text-align: center;">Minimum Thickness: 1-3/4"</p>

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) UL 10C (2001) UBC Standard 7-2 (1997)	<p>90 Minute-With Hose Stream</p> <p>Positive Pressure</p> <p>Category B-Requires Additional</p> <p>Listed Edge Seal</p> <p>For Use in Category C Steel Frame (or may also be installed in Category C - Proprietary, in accordance with individual manufacturer's listing)</p>

TEST REPORT
Intertek Test Report No: 3054678

Administrator's Signature: 

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com