

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012913-R3
DATE: 10/19/2015
CERTIFICATION PROGRAM: Fire
COMPANY: Dyke Industries
CODE: 452-1
REVISION DATE: 11/14/2023
EXPIRATION DATE: 10/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dyke Industries 10500 Northwest 95th Avenue Medley, FL 33178	90 Minute Positive Pressure Fire Door Assemblies w/o Hose Stream Manufacturer Specific Fire Doors for Single or Double Swing Installation in 90 Minute Locations 1/2" Minimum Latch Throw Single or Double Swing Only Maximum Size: 3'0" x 8'0" Maximum Size: 3'6" x 7'0" Maximum Size: 6'0" x 7'0" Minimum Thickness: 1-11/16"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008)/UL 10B (2009)/ UL 10C (2009)/UBC 7-2 (1997) CAN ULC S104 (2010)	90 Minute-Positive Pressure Without Hose Stream Category B - Additional Edge Sealing System Required

TEST REPORT
Intertek Test Report No: 100108677COQ-001, 100211525COQ-001, 100754937MID-001, J20012862-231, 3150506MID-004, 3025659

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com