

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012913-R4  
DATE: 10/19/2015  
CERTIFICATION PROGRAM: Fire  
COMPANY: Dyke Industries  
CODE: 452-1  
REVISION DATE: 05/28/2024  
EXPIRATION DATE: 10/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Dyke Industries</b> <b>10500 Northwest 95<sup>th</sup> Avenue</b> <b>Medley, FL 33178</b>	<b>90 Minute Positive Pressure Fire Door</b> <b>Assemblies w/o Hose Stream</b> Manufacturer Specific Fire Doors for Single or Double Swing Installation in 90 Minute Locations  1/2" Minimum Latch Throw Single or Double Swing Only  <b>Maximum Size: 3'0" x 8'0"</b> <b>Maximum Size: 3'6" x 7'0"</b> <b>Maximum Size: 6'0" x 7'0"</b> <b>Minimum Thickness: 1-11/16"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)/UL 10B (2009)/ UL 10C (2009)/UBC 7-2 (1997) CAN ULC S104 (2010)</b>	<b>90 Minute-Positive Pressure Without Hose Stream Category B - Additional Edge Sealing System Required</b>

TEST REPORT
<b>Intertek Test Report No: 100108677COQ-001, 100211525COQ-001, 100754937MID-001, J20012862-231, 3150506MID-004, 3025659</b>

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)

