

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013102-R3
DATE: 04/01/2016
CERTIFICATION PROGRAM: Fire
COMPANY: Palmer-Donavin
CODE: 941-1
EXPIRATION DATE: 04/30/2023
REVISION DATE: 08/08/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Palmer-Donavin Manufacturing Co. 1120 O'Neill Drive Hebron, OH 43025	JM Eagle 20 Minute Category C Proprietary Wood Composite Door Frames w/PVC Cladding Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations (Particle Board Core Wood, Fiberglass Skin, Steel Skin w/ Wood Edged Doors Only) Wood & Fiberglass Single Door Maximum Size: 3'0" x 8'0" Steel w/Wood Edge Single Door Maximum Size: 3'0" x 7'0" Minimum Thickness: 4-1/2"

SPECIFICATION	PRODUCT RATING
CAN4 S104 (1985)(2010) NFPA 252 (2008)(2012) UL 10C (2001)(2009)	20 Minute-Without Hose Stream Positive Pressure Category C- Proprietary Frame
TEST REPORT	
Intertek Test Report No(s): 3167720MID-004, 3167700MID-013, 3183953MID-001, 100142215MID-002b, 100529924MID-002R1, 101729929-001	

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124/ nami@namiinc.com