

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013405-R2
DATE: 11/03/2016
CERTIFICATION PROGRAM: Fire
COMPANY: Milliken
CODE: 994-1
REVISION DATE: 09/27/2021
EXPIRATION DATE: 11/30/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Milliken Millwork, Inc. 6361 Sterling Drive North Sterling Heights, MI 48312 | Plastpro's 60 Minute Positive Pressure Fire Door Assemblies w/Hose Stream Manufacturer Specific Fire Doors for Single Swing Installation in 60 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4" |

| SPECIFICATION | PRODUCT RATING |
|---|--|
| NFPA 252 (2008)(2012)/UL 10C (2009)/ CAN4 S104 (1985)/ CAN/ULC S104 (2010) | 60 Minute-Positive Pressure With Hose Stream Category B - Additional Edge Sealing System Required |

| TEST REPORT |
|--|
| Intertek Test Report No: 3175675MID-004, 3196317MID-001 |

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124/ Fax: (804) 684-5122