

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013500-R2  
DATE: 02/08/2017  
CERTIFICATION PROGRAM: Fire  
COMPANY: Monterey Door  
CODE: 2200-1  
REVISION DATE: 08/02/2023  
EXPIRATION DATE: 02/28/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Monterey Bay Door, Inc.</b>  <b>755 Vertin Avenue, Suite F</b>  <b>Salinas, CA 93901</b>	<b>Plastpro's 20 Minute Positive Pressure</b>  <b>Fire Door Assemblies w/o Hose Stream</b>  Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single or Double Swing Only  <b>Maximum Size: 3'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (1999)</b> <b>UL 10C (2009)</b> <b>UBC Standard 7-2 (1997)</b>	<b>20 Minute-Positive Pressure</b> <b>Without Hose Stream</b> <b>Category B Door-Additional Edge Seal Required</b> (unless specified in individual manufacturer's listing) <b>For Use in Category C Frame</b> (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
<b>Intertek Test Report No: 3182549MID-005, 100644112MID-002, 100644112MID-004, 3178456MID-003,</b> <b>3182549MID-005b, 100359215MID-010b</b>

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)