

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	NI013670-R6
DATE:	03/30/2017
CERTIFICATION PROGRAM:	Fire
COMPANY:	84 Lumber
CODE:	2201-1
REVISION DATE:	06/11/2024
EXPIRATION DATE:	03/31/2033

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>84 Lumber, Inc. 4287 Stough Road Concord, NC 28207</p>	<p>20 Minute Positive & Neutral Pressure Flush or Molded Interior Side-Hinged Door w/Particleboard Core</p> <p>Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations</p> <p>1/2" Minimum Latch Throw Single Swing Only</p> <p>Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"</p>

SPECIFICATION	PRODUCT RATING
<p>NFPA 252 (1999) UL 10(b) (2009) ASTM E2074 (2000) CAN4-S104(ULC S104) UBC Standard 7-2 (1994/1997) UL 10(c) (1998)</p>	<p>20 Minute-Neutral/Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small></p>

TEST REPORT
Intertek Test Report No: 3137713COQ-007

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com