NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013709-R2

DATE: <u>05/09/2017</u>

CERTIFICATION PROGRAM: Fire

COMPANY: Monterey Door

CODE: 2200-1

REVISION DATE: <u>08/02/2023</u> **EXPIRATION DATE:** <u>05/31/2025</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Monterey Bay Door, Inc.	20 Minute Positive & Neutral Pressure
755 Vertin Avenue, Suite F	Flush or Molded Interior Side-Hinged
Salinas, CA 93901	Door w/Particleboard Core
	Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations
	1/2" Minimum Latch Throw Single Swing Only
	Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999)	20 Minute-Neutral/Positive Pressure
UL 10(b) (2009)	With Hose Stream
ASTM E2074 (2000)	Category B Door-Additional Edge Seal
CAN4-S104(ULC S104)	Required
UBC Standard 7-2 (1994/1997)	For Use in Category C Frame
UL 10(c) (1998)	(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT

Intertek Test Report No: 3137713COQ-007

Administrator's Signature: _

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124/nami@namiinc.com