

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013743-R2  
**DATE:** 06/01/2017  
**CERTIFICATION PROGRAM:** Fire  
**COMPANY:** Harbin Lumber  
**CODE:** 2341-1  
**REVISION DATE:** 05/13/2025  
**EXPIRATION DATE:** 06/30/2035

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Harbin Lumber Company</b>  <b>660 Smith Road</b>  <b>Lavonia, GA 30553</b>	<p style="text-align: center;"><b>90 Minute Steel Single Swing Door</b></p> <p style="text-align: center;"><b>w/Bayer Baytherm 3003 Core</b></p> <p style="text-align: center;">22 Gauge Steel Skin Door w/Bayer Baytherm 3003 Core for single swing installation in 90 Minute locations</p> <p style="text-align: center;">1/2" Minimum Latch Throw Single Swing Only</p> <p style="text-align: center;"><b>Maximum Size: 3'0" x 6'8"</b> <b>914mm x 2032mm</b></p>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)</b> <b>UL 10C (2009)</b> <b>CAN4 S104(1985)</b>	<b>90 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>Category B Door-Additional Edge Seal</b> <b>Required</b> <b>For Use in Category C Frame</b>

TEST REPORT
<b>Intertek Test Report No: 3193924MID-007</b>

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC 03/30/2023

