

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013753-R1  
DATE: 06/14/2017  
CERTIFICATION PROGRAM: Fire  
COMPANY: Harvey  
CODE: 310-1  
REVISION DATE: 12/09/2021  
EXPIRATION DATE: 06/30/2031

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Harvey Building Products</b> <b>30 Jack's Bridge Road</b> <b>Londonderry, NH 03053</b>	<b>20 Minute Positive Pressure Steel Fire</b> <b>Door Assemblies w/o Hose Stream</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>Maximum Size: 3'0" x 7'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (1999)</b> <b>UL 10C (1998)</b> <b>UL 10B (1997)</b> <b>UBC Standard 7-2 (1997)</b>	<b>20 Minute-Positive Pressure</b> <b>Without Hose Stream</b> <b>Category B Door-Additional Edge Seal</b> <b>Required</b> (unless specified in individual manufacturer's listing) <b>For Use in Category C Frame</b> (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

## TEST REPORT

Intertek Test Report No: 3042535-1, 3042535-2  
NAMI Waiver of Retest: W-1653

A handwritten signature in black ink, appearing to be "Shi".

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)