

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013754-R1
DATE: 06/14/2017
CERTIFICATION PROGRAM: Fire
COMPANY: Harvey
CODE: 310-1
REVISION DATE: 12/09/2021
EXPIRATION DATE: 06/30/2031

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Harvey Building Products 30 Jack's Bridge Road Londonderry, NH 03053	90 Minute Steel Single Swing Door w/Bayer Baytherm 3003 Core 22 Gauge Steel Skin Door w/Bayer Baytherm 3003 Core for single swing installation in 90 Minute locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 6'8" 914mm x 2032mm

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10C (2009) CAN4 S104(1985)	90 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame

TEST REPORT
Intertek Test Report No: 3193924MID-007

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com