

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013763-R2  
DATE: 06/26/2017  
CERTIFICATION PROGRAM: Fire  
COMPANY: Harbin Lumber  
CODE: 2341-1  
REVISION DATE: 05/13/2025  
EXPIRATION DATE: 06/30/2035

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Harbin Lumber Company</b> <b>660 Smith Road</b> <b>Lavonia, GA 30553</b>	<b>20 Minute Category C</b> <b>Proprietary Wood Door Frames</b>  Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations  <b>Single Door Maximum Size: 3'6" x 7'0"</b>  <b>Minimum Thickness: 3-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>UL 10C (1998)</b> <b>UBC Standard 7-2 (1997)</b> <b>UBC Standard 7-2 (1994)</b>	<b>20 Minute-With &amp; Without Hose Stream</b> <b>Neutral Pressure</b> <b>Category C- Proprietary Frame</b>

TEST REPORT
<b>Warnock Hersey Test Report No: WHI-495-0509</b> <b>Intertek Test Report No(s): 3746699, 8772599, 3028781, 3035264, 3048460</b> <b>Priest &amp; Assoc. Engineering Evaluation No: 10260</b> <b>NAMI Waiver of Retest: W-1747</b>

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC 03/30/2023