

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013859-R4
DATE: 10/02/2017
CERTIFICATION PROGRAM: Fire
COMPANY: Palmer-Donavin
CODE: 941-1
EXPIRATION DATE: 10/31/2025
REVISION DATE: 06/19/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Palmer-Donavin Manufacturing Co. 1120 O'Neill Drive Hebron, OH 43025	20 Minute Positive Pressure Steel Fire Door Assemblies w/o Hose Stream Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 7'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) UL 10C (1998) UL 10B (1997) UBC Standard 7-2 (1997)	20 Minute-Positive Pressure Without Hose Stream Category B Door-Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 3042535-1, 3042535-2 NAMI Waiver of Retest: W-1653

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/nami@namiinc.com