

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013861-R3
DATE: 10/02/2017
CERTIFICATION PROGRAM: Fire
COMPANY: Palmer-Donavin
CODE: 941-1
EXPIRATION DATE: 10/31/2026
REVISION DATE: 08/08/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	
Palmer-Donavin Manufacturing Co. 1120 O'Neill Drive Hebron, OH 43025	20 Minute SmoothStar Fiberglass Door w/Proprietary Core (Simulated Panel Type or Flush) Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations Single Door Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10C (2009)(R2015) NFPA 252 (2012)	20 Minute-without Hose Stream Positive Pressure Category B- Additional Edge Sealing Required

TEST REPORT
Intertek Test Report No: 3033943, 3084465, 3176111MID-002, 3187023MID-002, 100354358MID-001, 100537989MID-001 & 102613119MID-004

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ nami@namiinc.com