

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013884-R1
DATE: 10/25/2017
CERTIFICATION PROGRAM: Fire
COMPANY: Milliken
CODE: 994-1
REVISION DATE: 09/27/2021
EXPIRATION DATE: 10/31/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Milliken Millwork, Inc. dba MMI Doors 6361 Sterling Drive North Sterling Heights, MI 48312	<p style="text-align: center;">20 Minute Category C</p> <p style="text-align: center;">Proprietary Wood Door Frames</p> <p style="text-align: center;">Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations</p> <p style="text-align: center;">Single Door Maximum Size: 3'0" x 8'0"</p> <p style="text-align: center;">Minimum Thickness: 4-9/16"</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;">NFPA 252 (1995) UL 10b (1997)(2009) CAN/ULC S104 (1980)(2010) UBC Standard 7-2 (1994)</p>	<p style="text-align: center;">20 Minute-With Hose Stream Neutral Pressure Category C- Proprietary Frame</p>

TEST REPORT
<p>Intertek Test Report No(s): J98027188-231</p>

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124/ Fax: (804) 684-5122