

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013885-R2
DATE: 10/25/2017
CERTIFICATION PROGRAM: Fire
COMPANY: Milliken
CODE: 994-1
DATE: 09/27/2021
EXPIRATION DATE: 10/31/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Milliken Millwork, Inc. dba MMI Doors 6361 Sterling Drive North Sterling Heights, MI 48312	20 Minute Category C Proprietary Wood Door Frames Manufacture Specific Fire Door Frames for Double Swing Installation in 20 Minute Locations Double Door Maximum Size: 8'0" x 9'0" Minimum Jamb Depth: 3.5"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10b (1997) UL 10c (2009) CAN/ULC S104 (2010) UBC Standard 7-2 (1994)	20 Minute-With Hose Stream Positive Pressure Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No(s): 101305789COQ-002, 101664134COQ-002 Intertek Engineering Evaluation No(s): 102343380MID-001

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122