

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013964-R2
DATE: 02/08/2018
CERTIFICATION PROGRAM: Fire
COMPANY: Gem State
CODE: 2403-1
REVISION DATE: 03/12/2024
EXPIRATION DATE: 02/28/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Gem State Doors & Millwork 608 Carnation Drive Nampa, Idaho 83653	Lynden 20 Minute L20SP Flush Particleboard Core Fire Door Assembly Manufacturer Specific Fire Doors for Single, Double Swing & Double Egress Installation in 20 Minute Locations 1/2" Minimum Latch Throw for Singles 3/4" Minimum Latch Throw for Double Single & Double Swing Only Single Maximum Size: 4'0" x 9'0" Double Maximum Size: 8'0" x 9'0" Double Egress Maximum Size: 8'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10C (2001)(2009) UBC Standard 7-2 (1997)	20 Minute-Positive Pressure With Hose Stream Category A Door-No Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in Welded or Knock-Down 16 & 18 Gauge Steel or Listed Category C Wood, Steel, Aluminum or Proprietary Frames (In accordance with individual manufacturer's listing)

TEST REPORT

Intertek Test Report No: 3052139/3060684/3075954/3157236

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC 03/30/2023