

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014032-R2
DATE: 04/30/2018
CERTIFICATION PROGRAM: Fire
COMPANY: Orepac
CODE: 1234-1
REVISION DATE: 04/11/2024
EXPIRATION DATE: 04/30/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Orepac Building Products, Inc. 30160 SW Orepac Avenue Wilsonville, OR 97070	FyreWerks FC-20 20 Minute Positive Pressure Glazed Radius Top Side-Hinged Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10(b) (2009) UBC Standard 7-4 (1994/1997) UL 10(c) (2009) NFPA 252 (2008/2012)	20 Minute-Positive Pressure Without Hose Stream Category A Door-No Additional Edge Seal Required For Use in Category C Frame <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small>

TEST REPORT
Intertek Test Report No: 100846880COQ-007

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023