

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014033-R1
DATE: 04/30/2018
CERTIFICATION PROGRAM: Fire
COMPANY: Orepac
CODE: 1234-1
REVISION DATE: 11/08/2022
EXPIRATION DATE: 04/30/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Orepac Building Products, Inc. 30160 SW Orepac Avenue Wilsonville, OR 97070	FyreWerks FC-20 20 Minute Positive Pressure Side-Hinged Door Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single & Double Swing Only Single Maximum Size: 4'0" x 8'0" Double Maximum Size: 7'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10(b) (2009) CAN/ULC-S104 (2015) UL 10(c) (2015) NFPA 252 (2012)	20 Minute-Positive Pressure w/Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small>

TEST REPORT
Intertek Test Report No: 3073306, 3084820, 3144298COQ-003, 3159384COQ-002, 3156802COQ-004, 3181657COQ-006, 3179089COQ-003, 10015449MID-001, 102627269MID-001, 103096847MID-001

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com