

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014033-R2
DATE: 04/30/2018
CERTIFICATION PROGRAM: Fire
COMPANY: Orepac
CODE: 1234-1
REVISION DATE: 04/11/2024
EXPIRATION DATE: 04/30/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Orepac Building Products, Inc. 30160 SW Orepac Avenue Wilsonville, OR 97070	FyreWerks FC-20 20 Minute Positive Pressure Side-Hinged Door Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single & Double Swing Only Single Maximum Size: 4'0" x 8'0" Double Maximum Size: 7'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10(b) (2009) CAN/ULC-S104 (2015) UL 10(c) (2015) NFPA 252 (2012)	20 Minute-Positive Pressure w/Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small>

TEST REPORT
Intertek Test Report No: 3073306, 3084820, 3144298COQ-003, 3159384COQ-002, 3156802COQ-004, 3181657COQ-006, 3179089COQ-003, 10015449MID-001, 102627269MID-001, 103096847MID-001


 Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com