

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014038-R1
DATE: 05/03/2018
CERTIFICATION PROGRAM: Fire
COMPANY: Victory Door
CODE: 2435-1
REVISION DATE: 03/21/2023
EXPIRATION DATE: 05/31/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Victory Doors & Millwork, Inc. 1309 North 39th Avenue Nampa, Idaho 83687	Lynden 20 Minute L20 MDF-R Fire Door Assembly Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 7'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008)(2012) UL 10C (2001)(2009) UL 10B (2008)(2009) UBC Standard 7-2 (1997) CAN/ULC S104 (2010)	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in ANSI-A155/UL-63 Steel Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 101318303COQ-002/101503991COQ-001

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com