NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014039-R1

DATE: 05/03/2018

CERTIFICATION PROGRAM: Fire

COMPANY: Victory Door

CODE: <u>2435-1</u>

REVISION DATE: <u>03/21/2023</u> EXPIRATION DATE: <u>05/31/2027</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Victory Doors & Millwork, Inc.	Lynden 20 Minute Profiled
1309 North 39th Avenue	Particleboard Core Fire Door Assembly
Nampa, Idaho 83687	Manufacturer Specific Fire Doors for Single and Double Swing Installation in 20 Minute Locations
	1/2" Minimum Latch Throw for Singles 3-Point Latching Hardware Required for Doubles Single & Double Swing Only
	Single Maximum Size: 3'0" x 8'0" Single Maximum Size: 3'6" x 7'0" Double Maximum Size: 6'0" x 7'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008)(2012) UL 10C (2001)(2009) UL 10B (2008)(2009) UBC Standard 7-2 (1997) CAN/ULC S104 (1980 (R1985))	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in ANSI-A155/UL-63 16-Gauge Steel Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)
	with individual mandracturer's insuring)

TEST REPORT

Intertek Test Report No: 3141706COQ-001

Administrator's Signature: _____

Shi

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com