NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014040-R1

DATE: 05/03/2018

CERTIFICATION PROGRAM: Fire

COMPANY: Victory Door

CODE: <u>2435-1</u>

REVISION DATE: <u>03/21/2023</u> EXPIRATION DATE: <u>05/31/2027</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION Lynden 20 Minute L20SP		
Victory Doors & Millwork, Inc.			
1309 North 39th Avenue	Wood Core Fire Door Assembly		
Nampa, Idaho 83687	Manufacturer Specific Fire Doors for Single and Double Swing Installation in 20 Minute Locations		
	1/2" Minimum Latch Throw for Singles 3/4" Minimum Latch Throw for Double Single & Double Swing Only		
	Single Maximum Size: 4'0" x 9'0" Single Maximum Size: 3'6" x 10'0" Double Maximum Size: 8'0" x 9'0"		
	Double Egress Maximum Size: 8'0" x 8'0" Dutch Door: 4'0" x 8'0"		
	Door w/Transom Maximum Size: 4'0" x 10'0" Transom Maximum Size: 3'0" x 3'4" Minimum Thickness: 1-3/4"		

NFPA 252 (2008)(2012)	20 Minute-Positive Pressure
UBC Standard 7-2 (1994)(1997)(2015) CAN/ULC \$104 (1985)(2010)	With Hose Stream ategory B Door-Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in Category C-Standard Frame or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT

Intertek Test Report No: 491-7972/3052139/3060684/3075954/3157236/103140421

Administrator's Signature: ___



NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com