## NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014041-R1

DATE: 05/03/2018

CERTIFICATION PROGRAM: Fire

**COMPANY:** Victory Door

CODE: <u>2435-1</u>

REVISION DATE: <u>03/21/2023</u> EXPIRATION DATE: <u>05/31/2027</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Victory Doors & Millwork, Inc.	Lynden 20 Minute L20SP Flush
1309 North 39th Avenue	Particleboard Core Fire Door Assembly
Nampa, Idaho 83687	Manufacturer Specific Fire Doors for Single, Double Swing & Double Egress Installation in 20 Minute Locations  1/2" Minimum Latch Throw for Singles 3/4" Minimum Latch Throw for Double Single & Double Swing Only
	Single Maximum Size: 4'0" x 9'0" Double Maximum Size: 8'0" x 9'0" Double Egress Maximum Size: 8'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10C (2001)(2009)	20 Minute-Positive Pressure
<b>UBC Standard 7-2 (1997)</b>	With Hose Stream
	Category A Door-No Additional Edge Seal Required (unless specified in individual manufacturer's listing)
	For Use in Welded or Knock-Down 16 & 18 Gauge Steel
	or Listed Category C Wood, Steel, Aluminum or
	Proprietary Frames
	(In accordance with individual manufacturer's listing)

## **TEST REPORT**

Intertek Test Report No: 3052139/3060684/3075954/3157236

Sh

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com