

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014067-R1
DATE: 05/21/2018
CERTIFICATION PROGRAM: Fire
COMPANY: Mac-Vann, Inc.
CODE: 2014-1
REVISION DATE: 02/14/2022
EXPIRATION DATE: 05/31/2026

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Mac-Vann, Inc. 4792 Rawls Church Road Fuquay-Varina, NC 27526	<p style="text-align: center;">Endura 20 Minute Category C</p> <p style="text-align: center;">Proprietary Wood Door Frames</p> <p style="text-align: center;">Manufacture Specific Fire Door Frames for Double Swing Installation in 20 Minute Locations</p> <p style="text-align: center;">Single Door Maximum Size: 8'0" x 9'0"</p> <p style="text-align: center;">Minimum Jamb Depth: 3.5"</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;"> NFPA 252 (2012) UL 10b (1997) UL 10c (2009) CAN/ULC S104 (2010) UBC Standard 7-2 (1994) </p>	<p style="text-align: center;"> 20 Minute-With Hose Stream Positive Pressure Category C- Proprietary Frame </p>

TEST REPORT
Intertek Test Report No(s): 101305789COQ-002, 101664134COQ-002 Intertek Engineering Evaluation No(s): 102343380MID-001

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com