

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014071-R1
DATE: 05/22/2018
CERTIFICATION PROGRAM: Fire
COMPANY: Mac-Vann, Inc.
CODE: 2014-1
REVISION DATE: 02/14/2022
EXPIRATION DATE: 05/31/2026

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Mac-Vann, Inc. 4792 Rawls Church Road Fuquay-Varina, NC 27526	20 Minute Positive Pressure Flush or Molded Interior Side-Hinged Door w/Wheatboard Core Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) UL 10(b) (1997/2009) CAN4-S104 (1985) UBC Standard 7-2 (1994/1997) UL 10(c) (2009)	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 3137714COQ-008

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com