NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI014175-R1**
DATE:	**08/16/2018**
CERTIFICATION PROGRAM:	**Fire**
COMPANY:	**Fortress**
CODE:	**2457-1**
REVISION DATE:	**11/09/2022**
EXPIRATION DATE:	**08/31/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Fortress Doors and Trim, LLC **216 South Clark Drive** **Tempe, AZ 85288**	**Terma-Tru 20 Minute Positive Pressure** **Steel Fire Side-Hinged** **Door Assemblies w/o Hose Stream** Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only **Maximum Size: 3'0" x 7'0"** **Minimum Thickness: 1-3/4"**

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) **UL 10C (1998)** **UL 10B (1997)** **UBC Standard 7-2 (1997)**	**20 Minute-Positive Pressure** **Without Hose Stream** **Category B Door-Additional Edge Seal Required** (unless specified in individual manufacturer's listing) **For Use in Category C Frame** (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 3042535-1, 3042535-2 **NAMI Waiver of Retest: W-1653**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com