

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014233-R3
DATE: 10/16/2018
CERTIFICATION PROGRAM: Fire
COMPANY: BMC Millwork
CODE: 1665-1
REVISION DATE: 06/29/2023
EXPIRATION DATE: 10/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
BMC Millwork Corporation 399 Northpoint Parkway Acworth, GA 30102	Endura 20 Minute Category C Proprietary Wood Door Frames Manufacture Specific Fire Door Frames for Double Swing Installation in 20 Minute Locations Single Door Maximum Size: 8'0" x 9'0" Minimum Jamb Depth: 3.5"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10b (1997) UL 10c (2009) CAN/ULC S104 (2010) UBC Standard 7-2 (1994)	20 Minute-With Hose Stream Positive Pressure Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No(s): 101305789COQ-002, 101664134COQ-002 Intertek Engineering Evaluation No(s): 102343380MID-001

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com