

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014313-R1
DATE: 01/14/2019
CERTIFICATION PROGRAM: Fire
COMPANY: Trimco Millwork
CODE: 868-1
REVISION DATE: 11/30/2022
EXPIRATION DATE: 01/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Trimco Millwork 1835 Commerce Avenue Boise, ID 83715	<p style="text-align: center;">Lynden 20 Minute L20SP</p> <p style="text-align: center;">Wood Core Fire Door Assembly</p> <p style="text-align: center;">Manufacturer Specific Fire Doors for Single and Double Swing Installation in 20 Minute Locations</p> <p style="text-align: center;">1/2" Minimum Latch Throw for Singles 3/4" Minimum Latch Throw for Double Single & Double Swing Only</p> <p style="text-align: center;"> Single Maximum Size: 4'0" x 9'0" Single Maximum Size: 3'6" x 10'0" Double Maximum Size: 8'0" x 9'0" Double Egress Maximum Size: 8'0" x 8'0" Dutch Door: 4'0" x 8'0" Door w/Transom Maximum Size: 4'0" x 10'0" Transom Maximum Size: 3'0" x 3'4" Minimum Thickness: 1-3/4" </p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;"> NFPA 252 (2008)(2012) UL 10C (2001)(2009)(2016) UL 10B (2008)(2009) UBC Standard 7-2 (1994)(1997)(2015) CAN/ULC S104 (1985)(2010) CSFM 43.7 </p>	<p style="text-align: center;"> 20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required <small>(unless specified in individual manufacturer's listing)</small> For Use in Category C-Standard Frame <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small> </p>

TEST REPORT
Intertek Test Report No: 491-7972/3052139/3060684/3075954/3157236/103140421

Administrator's Signature: _____ *AKD*

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com