

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014320-R1
DATE: 01/17/2019
CERTIFICATION PROGRAM: Fire
COMPANY: EL & EL Wood
CODE: 2195-1
REVISION DATE: 02/13/2023
EXPIRATION DATE: 01/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Metrie EL & EL, LLC 13855 Ramona Avenue Chino, CA 91710	Simpson Stile & Rail Single Swing Wood Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'6" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10b (2009) UL 10c (2009) (2015) (2016) CAN/ULC S104 (2010) (2015) UBC Standard 7-2 (1997)	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 3089369COQ-005, 3137943COQ-003, 3157209COQ-005

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124/nami@namiinc.com