

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014322-R1
DATE: 01/17/2019
CERTIFICATION PROGRAM: Fire
COMPANY: EL & EL Wood
CODE: 2195-1
REVISION DATE: 02/13/2023
EXPIRATION DATE: 01/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Metrie EL & EL, LLC 13855 Ramona Avenue Chino, CA 91710	"Simpson Stile & Rail" Wood-Faced Fire Door Assembly w/ Hose Stream Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations For use in any Category C - Standard or Proprietary Frame 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'6" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
CAN/ULC S104 (2010) UL 10B (2009)(2015) UL 10C (2009)(2015)(2016) NFPA 252 (2012)	20 Minute-Positive Pressure With Hose Stream Category B - Additional Edge Sealing Required

TEST REPORT
Intertek Test Report No: 3089369COQ-005; 3137943COQ-003; 3157209COQ-005; 102770454MID-001

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com