

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014335-R1
DATE: 01/28/2019
CERTIFICATION PROGRAM: Fire
COMPANY: Treasure Valley
CODE: 2517-1
REVISION DATE: 01/16/2023
EXPIRATION DATE: 01/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Treasure Valley Door & Trim, LLC 1150 West Taylor Avenue Meridian, ID 83642	FyreWerks FC-20 20 Minute Positive Pressure Glazed Radius Top Side-Hinged Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10(b) (2009) UBC Standard 7-4 (1994/1997) UL 10(c) (2009) NFPA 252 (2008/2012)	20 Minute-Positive Pressure Without Hose Stream Category A Door-No Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 100846880COQ-007

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'Shelby' or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com