

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	NI014338-R1
DATE:	01/28/2019
CERTIFICATION PROGRAM:	Fire
COMPANY:	Treasure Valley
CODE:	2517-1
REVISION DATE:	01/16/2023
EXPIRATION DATE:	01/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Treasure Valley Door & Trim, LLC</p> <p>1150 West Taylor Avenue</p> <p>Meridian, ID 83642</p>	<p>20 Minute Positive & Neutral Pressure</p> <p>Flush or Molded Interior Side-Hinged</p> <p>Door w/Particleboard Core</p> <p>Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations</p> <p>1/2" Minimum Latch Throw Single Swing Only</p> <p>Maximum Size: 3'0" x 8'0"</p> <p>Minimum Thickness: 1-3/4"</p>

SPECIFICATION	PRODUCT RATING
<p>NFPA 252 (1999)</p> <p>UL 10(b) (2009)</p> <p>ASTM E2074 (2000)</p> <p>CAN4-S104(ULC S104)</p> <p>UBC Standard 7-2 (1994/1997)</p> <p>UL 10(c) (1998)</p>	<p>20 Minute-Neutral/Positive Pressure</p> <p>With Hose Stream</p> <p>Category B Door-Additional Edge Seal</p> <p>Required</p> <p>For Use in Category C Frame</p> <p>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</p>

TEST REPORT
Intertek Test Report No: 3137713COQ-007

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com