

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014374-R1
DATE: 03/28/2019
CERTIFICATION PROGRAM: Fire
COMPANY: Orepac
CODE: 1234-1
REVISION DATE: 08/01/2023
EXPIRATION DATE: 03/31/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Orepac Building Products, Inc. 30160 SW Orepac Avenue Wilsonville, OR 97070	<p style="text-align: center;">Rogue Valley 20 Minute Positive Pressure MDF Side-Hinged Door Assembly</p> <p style="text-align: center;">Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations</p> <p style="text-align: center;">1/2" Minimum Latch Throw Single & Double Swing Only</p> <p style="text-align: center;">Single Maximum Size: 3'6" x 8'0" Double Maximum Size: 7'0" x 8'0" Minimum Thickness: 1-3/4"</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;">UBC-7-2-97 UL 10C (1998)(2009) NFPA 252 (1999) CAN4 S104 (1985) CAN/ULC S104 (2010)</p>	<p style="text-align: center;">20 Minute-Positive Pressure w/Hose Stream Category A Door-No Additional Edge Seal Required For Use in Category C Frame <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small></p>

TEST REPORT
Intertek Test Report No: 3049231/3049231a

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com