

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014376-R1  
DATE: 04/01/2019  
CERTIFICATION PROGRAM: Fire  
COMPANY: Orepac  
CODE: 1234-1  
REVISION DATE: 08/01/2023  
EXPIRATION DATE: 03/31/2025

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Orepac Building Products, Inc.</b> <b>30160 SW Orepac Avenue</b> <b>Wilsonville, OR 97070</b>	<b>Rogue Valley 20 Minute</b> <b>Positive/Neutral Pressure Panel-Type</b> <b>MDF Side-Hinged Door Assembly</b>  Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single & Double Swing Only  <b>Single Maximum Size: 3'6" x 8'0"</b> <b>Double Maximum Size: 7'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>UBC-7-2-94</b> <b>UL 10B (1997)(2009)</b> <b>UL 10C(2009)</b> <b>NFPA 252 (2003)(2012)</b>	<b>20 Minute-Positive Pressure w/o Hose Stream</b> <b>20 Minute-Neutral Pressure w/o Hose Stream</b> <b>Category A Door-No Additional Edge Seal Required</b> <b>For Use in Category C Frame</b> <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small>

TEST REPORT
<b>Intertek Test Report No: 3049231/3049231a</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)