

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI014430-R3</u>
DATE:	<u>06/03/2019</u>
CERTIFICATION PROGRAM:	<u>Fire</u>
COMPANY:	<u>BMC Millwork</u>
CODE:	<u>1665-1</u>
REVISION DATE:	<u>10/29/2025</u>
EXPIRATION DATE:	<u>06/30/2026</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
BMC Millwork Corporation 399 Northpoint Parkway Acworth, GA 30102	Woodgrain 20 Minute Category C Proprietary Wood Door Frames Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations Single Door Maximum Size: 3'6" x 7'0" Minimum Thickness: 3-3/4"

SPECIFICATION	PRODUCT RATING
UL 10C (1998) UBC Standard 7-2 (1997) UBC Standard 7-2 (1994)	20 Minute-With & Without Hose Stream Neutral Pressure Category C- Proprietary Frame

TEST REPORT
Warnock Hersey Test Report No: WHI-495-0509 Intertek Test Report No(s): 3746699, 8772599, 3028781, 3035264, 3048460

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com